

Air density (γ): 1.20 kg/m³
Installation type "B": free inlet, ducted outlet
12000 m³/h test chamber

Fan test laboratory according to AMCA 210/99 fig. 12

Fan type: DARE 9/9R XPL
Motor type: SM00003
Test nr.: 796
Date: 2014/08/08
Erp status: ErP 2015

Motor power [W]: 400
Power supply[V]: 230 1~
Frequency[Hz]: 50
Capacitor [μ F]: 10

Max. current [A]: 4.2
Prot. class: IP44
Ins. class: F
T.H.: YES-IN

